

Energy performance certificate (EPC)

14, Chapel Road Tuckingmill CAMBORNE TR14 8QY	Energy rating D	Valid until: 14 June 2025
		Certificate number: 8401-2023-7229-0797-6653

Property type

Mid-terrace house

Total floor area

59 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's current energy rating is D. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		86 B
69-80	C		
55-68	D	66 D	
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Wall	Cavity wall, as built, insulated (assumed)	Good
Wall	Solid brick, as built, insulated (assumed)	Good
Roof	Pitched, 250 mm loft insulation	Good
Roof	Flat, insulated (assumed)	Average
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good

Feature	Description	Rating
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	Portable electric heaters (assumed)	N/A

Primary energy use

The primary energy use for this property per year is 236 kilowatt hours per square metre (kWh/m²).

▶ [About primary energy use](#)

Additional information

Additional information about this property:

- Stone walls present, not insulated

How this affects your energy bills

An average household would need to spend **£626 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £148 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2015** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 6,504 kWh per year for heating
- 1,803 kWh per year for hot water

Impact on the environment

This property's current environmental impact rating is D. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year. CO₂ harms the environment.

Carbon emissions

An average household produces

6 tonnes of CO₂

This property produces

2.4 tonnes of CO2

This property's potential production

0.7 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

▶ [Do I need to follow these steps in order?](#)

Step 1: Internal or external wall insulation

Typical installation cost

£4,000 - £14,000

Typical yearly saving

£93

Potential rating after completing step 1

71 C

Step 2: Floor insulation (suspended floor)

Typical installation cost

£800 - £1,200

Typical yearly saving

£25

Potential rating after completing steps 1 and 2

72 C

Step 3: Solar water heating

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£31

Potential rating after completing steps 1 to 3

74 C

Step 4: Solar photovoltaic panels, 2.5 kWp

Typical installation cost

£5,000 - £8,000

Typical yearly saving

£295

Potential rating after completing steps 1 to 4

86 B

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme](https://www.gov.uk/apply-boiler-upgrade-scheme) (<https://www.gov.uk/apply-boiler-upgrade-scheme>). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

[Find ways to save energy in your home.](#)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name

Michael Udell

Telephone

(0)1736 711 483

Email

mikeudelldea@aol.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme

Quidos Limited

Assessor's ID

QUID201179

Telephone

01225 667 570

Email

info@quidos.co.uk

About this assessment

Assessor's declaration

No related party

Date of assessment

12 June 2015

Date of certificate

15 June 2015

Type of assessment

▶ [RdSAP](#)

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.